



Amspec Estonia OÜ
Fosforiidi 4, Maardu
74114 Harju maakond
Eesti
Reg. 14465642

SHORE TANK MEASUREMENT REPORT

| | |
|------------|------------|
| Report No. | AM21489/ 3 |
| Cargo | Diesel |

| | |
|----------------|------------------------|
| Installation | Nordic Storage (Malmö) |
| Shore Tank No. | M312 |

| Recorded measurement | | Observed Innage in mm | Total Observed Volume in m ³ Calib Tables | Total Observed Volume in m ³ **Corrected | Free water | | Gross Obs Volume in m ³ | Density Vac at 15°C in kg/m ³ | Temp in °C | V.C.F. Table 54B | Gross Std Volume in m ³ | Metric Tons (Vac) |
|----------------------|-------|-----------------------|--|---|------------|-----------------------|------------------------------------|--|------------|------------------|------------------------------------|-------------------|
| Date | Time | | | | Gauge mm | Volume m ³ | | | | | | |
| 04/11/2021 | 00:00 | 0 | 0.000 | 0.000 | 0 | 0.000 | 0.000 | 0.0 | 0.00 | | 0.000 | 0.000 |
| 04/11/2021 | 10:00 | 14661 | 18657.084 | 18657.084 | 0 | 0.000 | 18657.084 | 831.3 | 13.50 | 1.00129 | 18681.152 | 15529.642 |

| | |
|--------------------------------|------------------|
| Total Cu. M at 15 deg C | 18681.152 |
| Total Metric Tons (Vac) | 15529.642 |

All inspection work, sampling and quantity calculations were carried out in accordance following API MPMS standards :

Density determined according to ASTM D4052 – 18a

API MPMS Chapter 12.1.1 Calculation of Static Petroleum Quantities, Part 1—Upright Cylindrical Tanks and Marine Vessels Feb. 2019

Above results are valid for indicated time and place of inspection only.

Comments:

Measuring tape No.8705 - Certificate No.ATLL-18/0335 (31.01.2018)

Portable Electronic Thermometer TP-7 No. 7-12797 - Certificate No. ATLT-21/0766 (23.07.2021)

Tagatud on mõõtemääramatus 0.3 %, MKM nr. 103, (17.12.2007.a.)RTL 2008, 103, 1475 - jõust.01.01.2009

EAK L303

Inspector
Date

Andres Petuhov
04/11/2021