



Amspec Estonia OÜ
Fosforiidi 4, Maardu
74114 Harju maakond
Eesti
Reg. 14465642

SHORE TANK MEASUREMENT REPORT

Report No.	AM21340/ 1
Cargo	Diesel

Installation	Teboil Turku
Shore Tank No.	120

Recorded measurement		Observed Innage in mm	Total Observed Volume in m ³ Calib Tables	Total Observed Volume in m ³ **Corrected	Free water		Gross Obs Volume in m ³	Density Vac at 15°C in kg/m ³	Temp in °C	V.C.F. Table 54B	Gross Std Volume in m ³	Metric Tons (Vac)
Date	Time				Gauge mm	Volume m ³						
26/08/2021	00:00	0	0,000	0,000	0	0,000	0,000	0,0	0,00		0,000	0,000
26/08/2021	09:00	19142	9109,923	9109,923	0	0,000	9109,923	834,4	14,70	1,00026	9112,292	7603,296

Total Cu. M at 15 deg C	9112,292
Total Metric Tons (Vac)	7603,296

All inspection work, sampling and quantity calculations were carried out in accordance with the latest editions of API MPMS standards . Density determined according to ASTM D4052 standard.

**API MPMS Chapter 12, Section 1, Part 1 - Calculation of Static Petroleum Quantities

Above results are valid for indicated time and place of inspection only.

Comments:

Measuring tape No.8705 - Certificate No.ATLL-18/0335 (31.01.2018)

Portable Electronic Thermomemter TP-7 No. 7-12797 - Certificate No. ATLT-18/0123 (30.01.2018)

Tagatud on mõõtemääramatus 0.5 %, MKM nr. 103, (17.12.2007.a.)

Inspector
Date

Andres Petuhov
26/08/2021

